



Certificate of Compliance

Certificate: 2494369

Master Contract: 254100

Project: 70032715

Date Issued: November 2, 2015

Issued to: Electric Power Inc.

7686 Kimbel Street, Unit 18
Mississauga, ON L5S 1E9
Canada
Attention: Naseem Kalair

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Tai Pham

Issued by: Tai Pham

PRODUCTS

CLASS 5411 86 - TRANSFORMERS - Power - Certified to US Standards

CLASS 5411 06 - TRANSFORMERS-Power

Transformers, dry type, isolation and auto-transformer, types open core and coil assemblies or enclosed. Type ANN (ventilated), 600V max, 50Hz, 60Hz, 1-phase, 166 kVA max, 3-phase, 500 kVA max, class 220 Deg C system, 150 Deg C Rise. Enclosure rated Type 3R.

Notes:

These enclosures are not Certified separately, but are accepted components of CSA Certified power transformers covered in this file. The enclosure ratings are added to the nameplate of the Certified transformers.

Open core and coil assemblies are considered components where the combinations of the end product are to be evaluated by CSA Group or local authority having jurisdiction.

APPLICABLE REQUIREMENTS

CSA C22.2 No 47 - Air-Cooled Transformers (Dry-Type)

UL 1561 - Dry type General Purpose and Power Transformers